

1. DESIGN CRITERIA


- THE TANK AND SUPPORT STRUCTURE SHALL BE DESIGNED, FABRICATED, AND ERECTED IN ACCORDANCE WITH AWWA D100-11 AND THE PROJECT SPECIFICATIONS.
- 1.B. LOADING CRITERIA:
- 1.B.A. DESIGN WIND VELOCITY _ _ _ M
 1.B.B. DESIGN SNOW LOAD _ _ _ PSF
- 1.B.C. MCE SPECTRAL RESPONSE ACCELERATION 0.2 SEC PERIOD (S_S) _____
- 1.B.D. MCE SPECTRAL RESPONSE ACCELERATION 1.0 SEC PERIOD (S₁) _____

2. MATERIALS

- STEEL PLATE: ASTM A283 OR ASTM A36 2.A.
- 2.B. STRUCTURAL SHAPES: ASTM A36 OR ASTM A992
- LADDER RUNGS: ASTM A706

3. GENERAL

- ALL ACCESSORIES SHOWN ON THE ELEVATION DRAWING ARE ROTATED FOR CLARITY.
- THE NUMBER OF PERIMETER COLUMNS SHALL BE PER MANUFACTURER'S STANDARD DESIGN. 3.B.
- ALL LADDERS, LADDER SAFETY DEVICES, PLATFORMS, HANDRAILS, ETC. SHALL CONFORM TO CURRENT OSHA REGULATIONS.
- TANK CONTRACTOR SHALL GROUT BENEATH COLUMN AND RISER BASE PLATES UPON COMPLETION 3.D. OF ERECTION.
- SURFACE PREPARATION AND COATING REQUIREMENTS SHALL BE IN ACCORDANCE WITH THE 3.E. PROJECT SPECIFICATIONS.
- THE TANK SHALL BE DISINFECTED IN ACCORDANCE WITH AWWA C652-02.





JOB. No.

SHEET